

Select and print the following area

选中并打印以下区域

380v working area setting as the following configuration

380v工作区按照以下部分配置供电



L1/L2/L3/PE



Main breaker 主空开规格	3P-200A
Main cables 主线缆	3*120+1*70
Active power 有功功率	86.72
Total current 总电流	130.38
Apparent power 视在功率	108.40

Transformer
变压器

mm²

kw

A

kva

380v working area setting as the following configuration						
380v工作区按照以下部分配置供电						
Breaker 空开	4P-40A	Cables 线缆	5*10	Cabinet 床身电柜	13.8 26.2	kw A
Breaker 空开	3P-32A	Cables 线缆	4*16	Laser source 激光器	17.2 26.2	kw A
Breaker 空开	4P-25A	Cables 线缆	5*4	Chiller 水冷机	6.3 9.5	kw A
Breaker 空开	3P-32A	Cables 线缆	4*4	Purifier1 烟雾净化器1	7.5 15.7	kw A
Breaker 空开	NONE	Cables 线缆	NONE	Purifier2 烟雾净化器2	0.0 0.0	kw A
Breaker 空开	4P-63A	Cables 线缆	5*16	Compressor 空压机1	22.0 41.8	kw A
Breaker 空开	NONE	Cables 线缆	NONE	Compressor 空压机2	0.0 0.0	kw A
Breaker 空开	NONE	Cables 线缆	NONE	N2 Machine 制氮机	0.0 0.0	kw A
Breaker 空开	4P-32A	Cables 线缆	5*6	T-Trans2 自动化	10.0 18.9	kw A
Breaker 空开	4P-32A	Cables 线缆	5*6	M-UnLoader M下料自动化	10.0 19.0	kw A